



INDUSTRIAL TECHNOLOGY INSTITUTE (ITI)

P. O. Box, 787, 363, Bauddhaloka Mawatha, Colombo 7, Sri Lanka.

Telephone: 0094 011 2379800 Fax: 0094 011 2379850

120/4 A, Vidya Mawatha, Colombo 7, Sri Lanka.

Telephone: 0094 011 2379800 Fax: 0094 011 2379950

TEST REPORT

Report No. SS 1719632

Report to :

GB Coatings (Pvt) Ltd.,
No. 525/14, Thaladena Garden,
Thalangama North,
Battaramulla.

Issued By:

Materials Laboratory,
Industrial Technology Institute,
363, Bauddhaloka Mawatha,
Colombo 07.

2018-01-16

Page 01 of 03 Pages



TEST REPORT


Report No. SS 1719632

Customer : GB Coatings (Pvt) Ltd., No. 525/14, Thalahena Garden, Thalangama North, Battaramulla.	Test Item : Skim Coat Service Requested : Customer's request dated 2017-12-21
Description : One (01) test item.	Identification of Test Item: Test item was labelled as; Solakro Wall Finish Gray Colour 1kg WGF 70/12/2017 Date of Receipt of Test Item : 2017-12-26
Test Dates : From 2018-01-12 to 2018-01-16	

TEST RESULTS :

Test/ Unit	Test Method	Results	Requirements in ASTM C 475/C 475 M 02
1. Check cracking	ASTM C 474 : 05	Pass	No cracks in the thinner half of the wedge and no deep fissure cracks in the thicker half of the wedge.
2. Putrefaction		Pass	No putrefaction within 4 days.


.....
Authorized Signatory
C.N. Vitharana
Research Engineer
Materials Laboratory


.....
W. A. M. Priyanwada
Assistant Research Technologist